

## AIR STRIPPING IN INDUSTRIAL WASTEWATER TREATMENT

**A. Srinivasan, P. Chowdhury, T. Viraraghavan**

*Faculty of Engineering, University of Regina, Canada*

**Keywords:** Air stripping, Ammonia, VOC, Design, Packed tower.

### Contents

1. Introduction
  2. Process description
  3. Stripping theory
  4. Design considerations
  5. Design of Stripping Tower
    - 5.1 Evaluation of Equilibrium Data
    - 5.2 Estimation of Operating Data
    - 5.3 Mass Balance Analysis
    - 5.4 Selection of Column
    - 5.5 Column Diameter and Pressure Drop Calculation
    - 5.6 Estimation of Column Height or Number of Plates
      - 5.6.1 Packed Tower Design
      - 5.6.2 Plate Tower Design
    - 5.7 Design Criteria
  6. Ammonia Stripping
    - 6.1 Air stripping
    - 6.2 Steam Stripping
  7. VOC stripping
    - 7.1 VOC Emissions during Wastewater Collection and Treatment
    - 7.2 Sources of Organic Wastewater
    - 7.3 Removal of VOC by Air Stripping
    - 7.4 Air Stripping Followed By Off Gas Adsorption
    - 7.5 Membrane Based Air Stripping
- Glossary  
Bibliography  
Biographical Sketches

### Summary

In the past, the major objectives of wastewater treatment were the removal of suspended solids, biochemical oxygen demand and coliform bacteria. It is only very recently that the removal of inorganic nutrients, such as nitrogen has been brought into focus. Municipal wastewater and many industrial wastes are among the principal contributors of these nutrients to surface waters. The presence of organic compounds that are potentially hazardous or toxic in water bodies is made increasingly evident by advances in analytical methods. This has resulted in the development of new technologies for the removal of these compounds from raw potable surface and groundwater supplies, as well as from process stream wastewater. The removal of substances having reasonable equilibrium vapor pressures at ambient temperatures, including ammonia, and many

volatile organic compounds (VOCs), by any of the processes known as air or gas stripping has proven to be efficient. The countercurrent packed-tower type air stripper offers greater interfacial surface area for mass transfer of volatile organic compounds than other gas-stripping processes. This method therefore offers significant advantages in efficiency and overall cost when used for the removal of ammonia and volatile organic compounds from wastewater streams.

## 1. Introduction

Air stripping is a process by which a liquid, usually wastewater, is brought into intimate contact with a gas, usually air, so that some undesirable volatile substances present in the liquid phase can be released and carried away by the gas. Processes such as mechanical surface aeration, diffused aeration, spray fountains, spray or tray towers, and countercurrent packed towers are encompassed by the term air stripping. These procedures produce a condition in which a large surface area of the water to be treated is exposed to air, which promotes transfer of the contaminant from the liquid phase to the gaseous phase.

## 2. Process Description




Figure 1. Packed tower air stripper

The process consists of counter-current flow of water and air through a packing material. The packed tower consists of a cylindrical drum equipped with a gas inlet and distributing space at the bottom; a liquid inlet and distributor at the top; gas and liquid outlets at top and bottom, respectively; and a supported mass of inert solid shapes, called tower packing (Figure 1). In the traditional system, water is pumped to the top of the tower, and is allowed to flow down over the inert packing, while air is pumped countercurrent from the bottom of the tower. The contaminants of interest such as ammonia or volatile organic compounds (VOC) are stripped out of the water into the air stream. In practice, two methods are used to achieve contact between phases so that mass transfer can occur: (1) continuous contact and (2) staged contact. Different flow patterns used in practice include countercurrent, co-current and cross-flow. The most common flow pattern is countercurrent mode.

### 3. Stripping Theory

The ratio of the contaminant at equilibrium in the liquid phase,  $C_L$ , to the contaminant in the gaseous phase,  $C_G$ , is a relationship known as Henry's law:

$$H = \frac{C_G}{C_L} \quad (1)$$

where  $H$  is Henry's constant. Henry's constant is a property of the solute/solvent system and the temperature, and follows Van't Hoff's relationship.

$$\log H = \left( \frac{-H^\circ}{RT} \right) + k \quad (2)$$

where  $H^\circ$  = enthalpy change resulting from the dissolution of the compound in water;  
 $R$  = the universal gas constant;  
 $T$  = the absolute temperature; and  
 $k$  = a compound dependent constant.

The general form of the equation for the rate of mass transfer across the gas-liquid interface in a gas stripper is given by the equation:

$$\frac{1}{V} \frac{dm}{dt} = K_L a (C_L^* - C_L) \quad (3)$$

where  $V$  = the liquid volume,  $m^3$ ;  
 $m$  = the mass of the solute, kg;  
 $t$  = time, s;  
 $K_L$  = the overall liquid mass transfer coefficient, m/s;  
 $a$  = the specific interfacial area,  $m^2/m^3$ ;  
 $C_L$  = the bulk average concentration in the liquid phase,  $kg/m^3$ ;  
 $C_L^*$  = the liquid concentration in equilibrium with the gas phase concentration,  $C_G$ ,  $kg/m^3$ ; and  
 $K_L a$  = the transfer rate constant.

The rate constants for the local liquid and gas phase transfers,  $k_L$  and  $k_G$ , respectively, are related to the overall transfer rate constant by

$$K_L a = \left( \frac{1}{K_L a} + \frac{1}{K_G a H} \right)^{-1} \quad (4)$$

#### 4. Design Considerations

Stripping towers have diameters of 0.5 to 3 m and heights of 1 to 15 m. The height of the packed tower will affect the removal efficiency of the contaminant. The desired rate of flow of the liquid to be treated will determine the diameter of the air stripping column. The type of packing material will have an impact on the mass transfer rate, because the surface area of the packing provides the air-to-water interfacial area. The air-to-water ratio ranges from as low as 5 to several hundred and is controlled by flooding and pressure drop considerations. The ratio of air-to-water flow through the air stripper will control the removal rate of the contaminant. An increase in the air-to-water ratio will usually result in greater removal rates, up to a point at which entrainment of the liquid by the air flow occurs, resulting in a sharp increase in the air pressure drop through the stripping column. This phenomenon is known as flooding. The opposite condition occurs when the liquid flow rate is increased until the tower begins to fill with liquid. This is also referred to as flooding. The pressure drop in the tower should be between 200 to 400 N/m<sup>2</sup> per meter of tower height to avoid flooding. The designer must choose a gas velocity far enough from flooding velocity to ensure safe operation. The flooding velocity depends on the type and size of packing and liquid mass velocity. Lowering the design velocity increases the tower diameter without much change in required height, since lower gas and liquid velocities lead to a proportional reduction in mass-transfer rate. Channeling occurs when water flows down the tower wall rather than through the packing. Distribution plates must be placed approximately every 5 to 10 m in the tower immediately above each packing section to avoid this. Channeling is severe in towers filled with stacked packing than in dumped packings. Using a smaller size packing will reduce the tendency of flow to channel. In towers of moderate size channeling can be minimized by having diameter of the tower at least 8 times the packing diameter. A packing material that offers a large surface area for mass transfer will usually present more resistance to countercurrent air flow, causing a higher gas pressure drop. Different materials offer better resistance to corrosivity, encrustation, or unfavorable water conditions. Initial packing material selection can be made with one offering a very low gas pressure drop that allows an increase in removal efficiency.

#### 5. Design of Stripping Tower

The design procedure for a stripping tower consists of following steps:

1. Evaluation of equilibrium data;
2. Estimation of operating data;
3. Selection of column;
4. Column diameter and pressure drop calculation; and
5. Estimation of column height or number of plates.

### 5.1 Evaluation of Equilibrium Data

The equilibrium relationship is given by a plot of  $C_0'$ , mole fraction of solute in the liquid that is in equilibrium with the gas leaving the tower, against  $y_e$ , the mole fraction of solute in gas leaving the top of the tower.

Using Henry's law,  $y_e$  is defined as follows:

$$y_e = \frac{H}{P_T} C_0' \quad (5)$$

where,  $y_e$ =concentration of solute in gas leaving the top of the tower, moles of solute per mole of air

$H$  = Henry's law constant,  $\frac{atm(mole\ gas)/(mole\ air)}{(mole\ gas)/(mole\ water)}$

$P_T$  = total pressure

$C_0'$  = concentration of solute in liquid that is in equilibrium with the gas leaving the tower, moles of solute per mole of liquid.

### 5.2 Estimation of Operating Data

The operation data for isothermal system are the liquid rate and the terminal concentrations or mole fractions. The operating conditions in the column are described by an operating line which is obtained by a mass balance around the column.

### 5.3 Mass Balance Analysis

The mass balance analysis for a continuous stripping tower is given by (Figure 2):




Figure 2. Continuous countercurrent flow gas stripping tower.

Total moles in = Total moles out

Moles of solute entering in liquid stream + Moles of solute entering in gas stream =  
Moles of solute leaving in liquid stream + Moles of solute leaving in gas stream

$$LC_0 + Gy_0 = LC_e + Gy_e \quad (6)$$

where, L =moles of liquid per unit time

G=moles of incoming gas per unit time

C<sub>0</sub>=concentration of solute in liquid entering at the top of the tower, moles of solute per mole of liquid

C<sub>e</sub>=concentration of solute in liquid leaving the bottom of the tower, moles of solute per mole of liquid

y<sub>0</sub>=concentration of solute in gas entering the bottom of tower, moles of solute per mole of solute-free gas

y<sub>e</sub>=concentration of solute in gas leaving the top of the tower, moles of solute per mole of air;

$$\Rightarrow (Gy_0 - Gy_e) = (LC_e - LC_0)$$

$$\Rightarrow G(y_0 - y_e) = L(C_e - C_0)$$

$$\Rightarrow (y_0 - y_e) = L/G(C_e - C_0)$$

$$\Rightarrow \frac{L}{G} = \frac{(C_e - C_0)}{(y_0 - y_e)} \quad (7)$$

This is the equation of straight line known as operating line. On (x, y) coordinate it has a slope of (L/G) and pass through the point (C<sub>0</sub>, y<sub>0</sub>) and (C<sub>e</sub>, y<sub>e</sub>).

#### 5.4 Selection of Column

Parameter	Packed column	Plate column
Pressure drop	√	×
Flooding	×	√
Channeling	×	√
High foaming liquid	√	×
Liquid hold-up	×	√
Corrosive atmosphere	√	×
Sediment deposition	×	√
Temperature change problem	×	√
Total weight	×	√
Small column	√	×
Large column	×	√

Note # √: more favored; ×: less favored;

Table 1. Comparison of packed and plate column

Packed column and plate columns are generally used in industrial stripping operations. Although packed columns are used more often in air pollution control, both have their special area of usefulness. Their relative advantages and disadvantages are presented in Table 1.

### 5.5 Column Diameter and Pressure Drop Calculation

The minimum possible diameter of stripping tower is determined from flooding velocity. Generally the column design velocity ranges from 60 to 80 % of the flooding velocity. For liquids having foaming tendency the maximum allowable velocity will be lower than the estimated flooding velocity, especially for plate tower. Pressure drop for packed column can be correlated with the column operating data, packing type, and physical properties of the constituent involved. The maximum allowable pressure drop can be determined by the cost of energy for compression of the feed gas. Figure 3 shows the correlation of flooding and pressure drop in a packed tower.




Figure 3. Flooding and pressure drop correlations for packed towers. [ $C_s$ =capacity parameter,  $F_p$ =packing factor,  $\nu$ =kinematic viscosity of liquid,  $\rho_G$ ,  $\rho_L$ =gas and liquid density]

-  
-  
-

TO ACCESS ALL THE 24 PAGES OF THIS CHAPTER,  
Visit: <http://www.eolss.net/Eolss-sampleAllChapter.aspx>

## Bibliography

De Renzo D.J. (1978). Unit operations for treatment of hazardous industrial wastes. Noyes Data Corporation, Park Ridge, New Jersey, U. S. A. pp. 869-897. [This book describes various unit operations such as flotation and stripping for treatment of hazardous industrial wastes].

Design Guide No. 1110-1-3. (2001). Engineering and Design air stripping. Department of the army, U. S. Army Corps of Engineers, Washington, DC 20314-1000. [This design guide provides design and construction information for implementation of air stripping systems].

LaGrega, M. (1993). Hazardous Waste Management. McGraw Hill Inc. [This book provides background information on hazardous wastes, its treatment and disposal methods and site remediation techniques].

Metcalf and Eddy (2003). Wastewater Engineering Treatment and Reuse. 4<sup>th</sup> Ed. Tata McGraw-Hill. New Delhi. 1162-1180. [This book is an update of an earlier book on wastewater treatment by McGraw-Hill. This revision contains a strong focus on advanced wastewater treatment technologies and reuse aspects of wastewater and biosolids].

O'Farrell T.P., Bishop, D.F. and Cassel A.F. (1973). Nitrogen Removal by Ammonia Stripping. EPA Report 670/2-73-040. [The report examines the removal of ammonia from lime clarified filtered wastewater using a five stage counter current cross flow stripping tower].

Perry R.H., Green D.W. and Moloney J.O. (1997). Perry's Chemical Engineers' Handbook. 7<sup>th</sup> Ed. McGraw-Hill. pp. 14-1 – 14-12. [This handbook covers all aspects of chemical engineering, from the fundamentals to details on computer applications and control].

Reynolds J.P., Jeris J.S. and Theodore L. (2002). Handbook of Chemical and Environmental Engineering Calculations. John Wiley & Sons., New York. pp. 392-413. [This book provides solutions to environmental problems that involve chemical engineering].

South Tahoe Public Utility District, (1971). Advanced Wastewater Treatment as Practiced at South Tahoe. EPA Report 1701OELQ 08/71. [This report provides data collected in pilot scale tests conducted at South Tahoe, in particular it gives the correlation between percent ammonia removal and surface loading rates for various depths of packing in a stripping tower].

Strigle R.F.Jr. (1994). Packed Tower Design and Applications: Random and Structured Packings. 2<sup>nd</sup> Ed., Gulf Publishing Company, Houston, Texas. pp. 92-112. [This book provides detailed design and applications of packed bed towers].

Tsai K-C., Shelby S.E.Jr. (1981). Air and steam stripping of high-strength ammonia wastes. Proceedings of the 36<sup>th</sup> Industrial Waste Conference May 12, 13 and 14. Purdue University Lafayette, Indiana. [The research paper investigates the potential of removing ammonia nitrogen from a chemical manufacturing plant wastewater by both air and steam stripping processes].

US EPA, (2000). Wastewater technology fact sheet ammonia stripping. EPA 832-F-00-019. [Fact sheet that describes a stripping process for lowering the ammonia content of a wastewater stream by adding lime or caustic agents].

U.S. EPA, (1975). Technology Transfer. Process design manual for nitrogen control. pp. 8-1 – 8-21. [A comprehensive discussion of chemical pathways, design elements, modelling parameters and nitrogen control technologies].

Wickramanayake G.B., Evers D.P. and Gavaskar, A. (1992). Bench-scale evaluation of ammonia removal from wastewater by steam stripping. US EPA Project Summary. EPA/600/S2-91/046. [This report studies ammonia removal from synthetically compounded wastewater samples using a bench-scale steam stripping apparatus to support the development of wastewater discharge standards for ammonia in nonferrous metal winning processes].

Zeng L., Mangan C. and Li X. (2006). Ammonia recovery from anaerobically digested cattle manure by steam-stripping. *Water Science and Technology*, 54(8), 137-145. [The paper examines the feasibility of removing ammonia from anaerobically digested cattle manure effluents using steam stripping at different feed pH values, ammonia concentrations and temperatures].



Zibrida J.F. and Fla St.P. (1987). Removal of ammonia from wastewater. United States Patent Number: 4,689,156. [The patent reports a method by which ammonia can be removed from wastewater involving treatment of the wastewater with an alkali reagent followed by gas-stripping].

### **Biographical Sketches**

**A. Srinivasan** is presently pursuing her doctoral degree in Environmental Engineering at the University of Regina, Regina, Saskatchewan, Canada. She graduated in Chemical Engineering from the University of Madras in 2003. She obtained a Master's degree in Environmental Management from Anna University, Chennai in 2005 through the Centre for Environmental Studies, College of Engineering, Guindy.

**P. Chowdhury** is a Ph. D. student in environmental engineering at the University of Regina, Regina, Saskatchewan, Canada. He obtained his Bachelor of Science in Chemistry from St. Paul's CM College, Kolkata, India in 1999. Then he completed Bachelors and Master's in Chemical Engineering from the University of Calcutta (Kolkata, India) in 2002 and 2004, respectively. He worked as a research engineer with Ballarpur Industries Ltd. (Gurgaon, India) and Thapar Centre for Industrial Research and Development (Patiala, India) during 2004 – 2006.

**T. Viraraghavan** graduated in civil engineering from the University of Madras in 1955 from the College of Engineering, Guindy, Madras, India. He worked for the Government of Tamil Nadu (Madras) for 10 years as Assistant Public Health Engineer and later for 5 years for the Government of India as Assistant Adviser in Public Health Engineering for the Ministry of Works and Housing. During 1962–63, he completed an M.Sc. in Public Health Engineering. He attended the University of Ottawa, Canada, during 1970–75 and obtained a doctorate in Civil Engineering in 1975. Dr. Viraraghavan worked as a senior environmental engineer with ADI Limited, Consulting Engineers, Fredericton, N.B. during 1975–82. He joined the Faculty of Engineering, University of Regina, Regina, Saskatchewan in 1982; presently he is Professor Emeritus of Environmental Engineering. He is a member on the editorial board of many journals, and is a member of many professional societies. He has a number of publications to his credit in national and international journals.